

## Application

Time control

# Description

The **ZAW1 Pulse-on release timer** offers 16 different timing intervals in one unit. The timing intervals can be adjusted with DIP switches on the front panel of the relay. The timer can operate on either 230V AC using terminals A1 and A2 or 24V DC using terminals A3 and A2. The green LED indicates the connection to the power supply.

# Function

Continuous presence of the power supply connected to the terminals A1 and A2 or A3 and A2 is required for timing. The activation of the timing function is accomplished with a potential-free control contact, which is connected to the terminals B1 and B2. When the power supply is applied, the control contact is opened, the output relay is energized and the timing is started. The output relay stays active for the set pulse time and is de-energized after this time has elapsed. The red LED indicates the working position of the control contact. If during or upon completion of the timing function the control contact is closed and reopened the timing period begins anew. This also applies if the supply is disconnected during the timing period.

## Options

Other timing ranges and voltages available upon request.

#### Part number

011212 ZAW1 Pulse-on release 16 Timing ranges / 1 Changeover


#### Timer ZAW1 - Pulse-on release with 1 Changeover 17.5mm housing

## **Timing ranges**

16 timing ranges with adjustable DIP switches


0.05 – 1 s 0.15 – 3 s	0.5 – 10 min 1.5 – 30 min
0.15 - 3.5 0.5 - 10.5	3 - 60  min
1.5 – 30 s	15 – 300 min
3–60 s	0.5 <i>—</i> 10 h
5 – 100 s	1.5 – 30 h
10 – 200 s	3 – 60 h
15–300 s	5 – 100 h

## **DIP** switch adjustments



# Approvals

# Function diagram



# Mounting

Snap-on mounting using a standard DIN rail EN 50022. The unit is designed to allow side-by-side mounting, with an ambient temperature of  $< 60^{\circ}$ C.



## **Technical data**

#### Supply

Supply voltage

Frequency range: Power consumption:

Operating mode: Supply voltage influence:

Temperature influence: Recovery time: Repetitive accuracy:

#### **Operation indicators**

Supply voltage: Relay in working position:

#### Contact

Number of changeovers: Contact material: Maximum switching voltage: Maximum switching current: Drop-off time of switching element: Mechanical life: Electrical life (with rated load):

#### General data

Ambient temperature: Climate resistance: Mounting position: Vibration resistance: Test voltage: Isolation group:

Protection class:

Connection terminals:

Connection cross section:

Finger touch protection:

Mounting:

Dimensions I x w x h: Weight: A1/A2: 230V AC -15 / +10% A3/A2: 24V AC/DC -15 / +10% 0 / 50 ... 60Hz approx. 1.5W with DC approx. 6VA with AC continuous : < 0.01% over voltage range


> < 0.01%/°C < 100ms ± 0.2%

LED, green LED, red

1 AgSnO<sub>2</sub> 250V AC 4A approx. 20ms 30 Mio. 0.8 Mio.


- 25 ... + 60°C VDE 0435T.2021 any VDE 0435T.2021 2.5kV VDE 0110 Group C 250 **Terminals IP 20** Housing IP 40 Crosshead screws; M3.5 self-opening Multi-strand wire with wire sleeves 2 x 2.5mm<sup>2</sup> single-wire 2 x 2.5mm<sup>2</sup> VDE 0106T.100 and VBG4 Symmetrical rail DIN EN 50022 90mm x 17.5mm x 69.5mm 96g

#### Example



When the contact S1 opens, K2 energizes immediately and the light H1 goes off. After completion of the selected timing K2 returns to its rest position and the light H1 comes on.

#### Dimensions



# Connections

The terminal assignment for the connections is located on the front panel of the relay. **Reading the front panel from top to bottom**, the connections are in the following order:

LED side	Right:	B1 – nc – A3
	Left:	nc – nc – A1
Potentiometer side	Right:	B2 – 15 – 18
	Left:	nc – A2 – 16

上海悦中电气设备有限公司 上海恒通路360号一天下大厦24C TEL:021-62246890 FAX:021-52240873 Http://www.skjd.cn E-mail:shskjd@126.com

