



防爆合格证

证号: GYJ12.1217X

由 重庆横河川仪有限公司

制造的产品:

(地址: 中国·重庆市·北部新区黄山大道中段61号)

名称 压力变送器

型号规格 EJA系列

防爆标志 Ex d IIC T4~T6 Gb
DIP A21 T_A85°C/100°C/120°C IP66/IP67

产品标准 /

图样编号 DKE027-A10

经图样及技术文件的审查和样品检验, 确认上述产品符合 GB 3836.1-2010、GB 3836.2-2010、GB 12476.1-2000 标准,

特颁发此证。北京中沃瑞源电力科技有限公司

本证书有效期: 2012年6月4日至2017年6月3日

- 备注
1. 安全使用注意事项见本证书附件。
 2. 证书编号后缀“X”表明产品具有安全使用特殊条件, 内容见本证书附件。
 3. 型号规格说明见本证书附件。
 4. [更改 I] 防爆标志增加IP66, 2013年2月27日签发。

站长

国家级仪器仪表防爆安全监督检验站

颁发日期二〇一二年六月四日



本证书仅对与认可文件和样品一致的产品有效。

地址: 上海市漕宝路103号
邮编: 200233

网址: www.nepsi.org.cn
Email: info@nepsi.org.cn

电话: +86 21 64368180
传真: +86 21 64844580



EXPLOSION PROTECTION CERTIFICATE OF CONFORMITY

Cert NO.GYJ12.1217X

This is to certify that the product

Pressure Transmitter

manufactured by **Yokogawa Sichuan Instrument Co., Ltd.**
(Address:No.61 Middle Section of Huangshan Ave,New North Zone,
Chongqing,China)

which model is **EJA7 Series**

Ex marking **Ex d II C T4~T6 Gb**
DIP A21 T_A85°C/100°C/120°C IP66/IP67

product standard /

drawing number **DKE027-A10**

has been inspected and certified by NEPSI, and that it conforms
to **GB 3836.1-2010,GB 3836.2-2010,GB 12476.1-2000**

This Approval shall remain in force until **2017.06.03**

Remarks 1.Conditions for safe use are specified in the attachment to this certificate.
2.Symbol "X" placed after the certification number denotes specific conditions of use,
which are specified in the attachment to this certificate.
3.Model designation is specified in the attachment to this certificate.
4.[Variation I] IP66 add to Ex Marking, issued on 2013.02.27.

Director

**National Supervision and Inspection Centre for
Explosion Protection and Safety of Instrumentation**

Issued Date 2012.06.04

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.

103 Cao Bao Road
Shanghai 200233, China

<http://www.nepsi.org.cn>
Email: info@nepsi.org.cn

Tel: +86 21 64368180
Fax: +86 21 64844580